

NOTE:
THE CONTRACTOR IS TO VERIFY THE DIMENSIONS OF
THE MECHANICAL ROOM AND THE PROPOSED
EQUIPMENT PRIOR TO INSTALLATION.

FOR HEALTH DEPARTMENT APPROVAL

This sheet is incomplete and invalid without each and every other sheet usted in the title box under the heading w.c.h.d. sheet No. $_$ of $_$.

2/6/16 ORIGINAL PREPARATION DATE
DATE DESCRIPTION

WASHINGTON'S HEADQUARTERS SWIMMING POOL

VILLAGE OF DOBBS FERRY WESTCHESTER COUNTY, NEW YORK

POOL AREA PLAN


DRAWING TITLE


SIGNATURE DATE
NUMBER OF ALTRAMON OF ACOTION TO A FLAN BLANKE A LICENSED LING
UNITED SON PROTESSION, LOCKERS SUL IS A VOLATOR OF SECTION FELL
UNITED SON OF THE MY, STATE EQUATION LIM.

JOHN PETROCCIONE P.E., PLC

LICENSE NO. 078516 129 NEPTUNE DRIVE, MONROE, NEW YORK 10950 (845) 782-7725

SCALE	PROJECT	CAD REFERENCE WHO MECH RM
1"=1"	armeters medianing	
NYSDEC DWG.NO	WCHD DWG.NO	DWG.NO





SWIMMING POOL EQUIPMENT LIST

THIS EQUIPMENT LIST IS BASED UPON AN AS-BUILT FINAL INPECTION PERFORMED ON

GENERAL NOTES:

THE POOL'S ELECTRICAL SYSTEM AND ALL OTHER WRING SHALL CONFORM TO ARTICLE 680 OF THE NATIONAL ELECTRICAL CODE. ALL LIGHTING AND ELECTRICAL CICERCUITS PROVIDED IN THE POOL AREA AND MECHANICAL ROOM ARE TO BE PROTECTED BY GROUND FAULT CIRCUIT INTERRUPTERS IN ACCORDANCE WITH THE UNIFORM CODE & THE NATIONAL ELECTRIC CODE, ALL ELECTRICAL FIXTURES SHALL BE

U.L. APPROVED.
THE EQUIPMENT ROOM IS TO BE PROVIDED WITH ARTIFICIAL LIGHTING SUFFICIENT TO CLEARLY ILLUMINATE ALL AREAS OF THE ENCLOSED

THE MECHANICAL ROOM IS TO BE PROVIDED WITH A VENTILATION THE MECHANICAL ROOM IS TO BE PROVIDED WITH A VENTILATION SYSTEM IN ACCORDANCE WITH ALL APPLICABLE CODES. AT A MINIMUM THE VENTILATION SYSTEM OF THE MECHANICAL ROOM SHALL BE SUFFICIENT TO PROVIDE 2 AIR CHANGES PER HOUR. SHOULD THE BUILDINGS HVAC SYSTEM BE INADEQUATE TO MEET THIS REQUIREMENT, VENTILATION SHALL BE PROVIDED THROUGH THE USE OF A FAN WITH LOUVERED VENTS OPEN TO THE OUTDOORS. THE HEATING EQUIPMENT SHALL BE INSTALLED AND VENTED TO THE OUTDOORS IN ACCORDANCE WITH THE MANUFACTURERS SPECIFICATIONS AND THE UNIFORM CODE. THE POOL BUILDER SHALL PROVIDE AN OPERATION MANUAL, INCLUDING FULL OPERATING INSTRUCTIONS FOR THE SALT CHLORINE GENERATING SYSTEMS. DRAWINGS, ILLUSTRATIONS AND PARTS LISTS SHALL BE INCLUDED ALONG WITH INSTRUCTIONS FOR THE FORTATION AND MAINTENANCE OF THE EQUIPMENT. THE MANUAL SHALL BE SUBMITTED TO, AND APPROVED BY THE WESTCHESTER COUNTY DEPARTMENT OF HEALTH.

TO, AND APPROVED BY THE WESTCHESTER COUNTY DEPARTMENT OF HEALTH.

POOL WATER MUST BE HELD FOR TEN DAYS PRIOR TO DISCHARGE TO ALLOW THE CHLORINE TO DISSIPATE. WATER BEING DISCHARGED MUST ALSO BE FREE OF ANY OTHER POLLUTANTS INCLUDING, BUT NOT LIMITED TO SLIMICIDES, BIOCIDES, ALGAECIDES, DETERGENTS AND CLEANERS.

CLEANERS.

8. ALL HOSE BIBS IN THE POOL AREA ARE TO BE PROVIDED WITH VACUUM BREAKERS.

9. ALL PIPING IS TO BE EITHER SCHEDULE 80 OR SCHEDULE 40 RIGID

VACUUM BERAKENS.

9. ALL PIPING IS TO BE EITHER SCHEDULE 80 OR SCHEDULE 40 RIGID PVC.


10. THE CONTRACTOR SHALL REVIEW ALL MANUFACTURERS RECOMMENDATIONS AND REQUIREMENTS FOR ALL COMPONENTS TO BE INSTALLED. ANY REQUIREMENTS OR RECOMMENDATIONS REQUIRING DEVIATION FROM THE APPROVED PLANS SHALL REQUIRE PRIOR APPROVAL BY THE DESIGN ENGINEER AND/OR THE DEPARTMENT OF

DEVIATION FROM THE APPROVED PLANS SHALL REJOINE PRIOR APPROVAL BY THE DESIGN ENGINEER AND/OR THE DEPARTMENT OF HEALTH.

1. AN ELECTRICAL INTERLOCK SHALL BE PROVIDED FOR THE CHEMICAL PUMPS, THEY SHALL BE HARD WIRED TO THE RECIRCULATION PUMP FOR THE POOL WHICH THEY SERVE, SUCH THAT THE CHEMICAL PUMPS WILL CEASE TO OPERATE IF THE RECIRCULATION PUMP IS NOT RUNNING, EITHER AN AUDIBLE ALARM OR LIGHT, VISIBLE IN THE POOL AREA SHALL BE PROVIDED TO INDICATE THAT EITHER PUMP IS NOT OPERATING.

12. THE LIQUID CHLORINE PUMP IS PROVIDED FOR POOL SHOCKING PURPOSES ONLY. THE SALT CHLORINE GENERATOR AND LIQUID CHLORINE PUMP ARE NOT TO BE USED SIMULTANEOUSLY. THE LIQUID CHLORINE PUMP IS TO BE OPERATED MANUALLY, AND NOT CONNECTED TO THE AUTOMATED CHEMICAL CONTROLLER.

13. THE SALT CHLORINE GENERATOR HAS AN OPERATING SALINITY LEVEL RANG OF 3500 - 5000 PW. THE OPERATOR SHALL CHECK THE SALINITY LEVELS AND RECORD THEM IN THE POOL OPERATIONS MANUAL ON A DAILY BASIS, AND MAKE ADJUSTMENTS. AS NEGEOL, TO OBTAIN THE OPTIMAL LEVEL. THE POOL SHALL NOT BE UTILIZED IF THE SALINITY LEVELS ARE NOT WITHIN THE OPERATIONAL RANGE.



MECHANICAL ROOM PHASE 3 (BUILD-OUT) SECTION VIEW SCALE 1"=1

COLOR CODING.
ALL EXPOSED PIPING SHOULD BE COLOR CODED IN ACCORDANCE WITH THE FOLLOWING TABLE: PIPING COLOR CODE
POTABLE WATER LINES DARK BLUE
FLITERED WATER ADUA
SKIMMER OR GUTTER RETURN DLIVE GREEN
MAIN DRAIN
GRANGE WASTE LINES
BACKWASH WASTE
SEWER (SEWER OR OTHER)
DECK DRAINS

COLOR CODE
DARK BROWN
LIGHT BROWN ALUM CHLORINE (GAS/SOLUTION) SODA ASH ACID DARK GREEN COMPRESSED AIR YELLOW WHITE PINK GAS

2/8/18 ORIGINAL PREPARATION DATE DATE DESCRIPTION WASHINGTON'S HEADQUARTERS **SWIMMING POOL** VILLAGE OF DOBBS FERRY WESTCHESTER COUNTY, NEW YORK **POOL AREA PLAN**

FOR HEALTH DEPARTMENT APPROVAL

THIS SHEET IS INCOMPLETE AND INVALID WITHOUT EACH AND EVERY OTHER SHEET USTED IN THE TITLE BOX UNDER THE HEADING W.C.H.D. SHEET NO. _ OF _ .

DATE
NUMBERS ALTRIANO DE ADMON TO A PUN BOANE A UCRASO UNO
RECTORS DE PROFESSORI, ENGICERS SEAL À A VOLATION OF SECTION 32
RE-DIVIGIO 3 OF THE MX. STATE EDUCATION UM.

JOHN PETROCCIONE P.E., PLLC LICENSE NO. 078516
128 NEPTUNE DRIVE, MONROE, NEW YORK 10950
(845) 782-7725

CAD REFERENCE PROJECT ASSESSMENT BLOCKING WHO MECH RM 1"=1" NYSDEC DWG.NO N/A of N/A 3 of 3

NOTE:
THE CONTRACTOR IS TO VERIFY THE DIMENSIONS OF
THE MECHANICAL ROOM AND THE PROPOSED
EQUIPMENT PRIOR TO INSTALLATION.